

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0085CR0400

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Distributor <i>Vertreiber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Condensing boiler with fan-assisted burner in modulating operation method and with enclosed combustion chamber
Model <i>Modell</i>	LAMBORGHINI CALORCLIMA iXINOX...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	type testing: K 1837 2018 B14 from 02.07.2018 (TRG) supplement test: K 1837 2018 E13 from 02.07.2018 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)
Date of Expiry / File No. <i>Ablaufdatum / AZ</i>	04.07.2028 / 21-0575-GEA

7028/04-A-DE

06.12.2021 Pz A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz
Elektrische Daten

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I12ELw	20 mbar	PL	
I12E+3P	20/25, 30 mbar	BE, FR	
I12E+3P	20/25, 37 mbar	BE, FR	
I12EK3B/P	20/25, 30 mbar	NL	
I12ELL3B/P	20, 50 mbar	DE	
I12ELw3B/P	20, 30 mbar	PL	
I12H3B/P	20, 30 mbar	CY, DK, EE, FI, HR, IE, IS, IT, LT, NO, RO, SE, SI, SK, TR	
I12H3B/P	20, 37 mbar	GR, IE, LV	
I12H3B/P	20, 50 mbar	AT, CH, CZ, HR, LU	
I12H3P	20, 37 mbar	ES	
I12HS3B/P	25, 30 mbar	HU	
I12HS3B/P	25, 50 mbar	HU	
I12L3B/P	25, 30 mbar	NL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
LAMBORGHINI CALORECLIMA iXINOX 25 K 50	nominal heat output: 5,7...24,5 kW heat input (Hi): 5,8...25,0 (drinking water: ...27,5) kW	
LAMBORGHINI CALORECLIMA iXINOX 32 K 50; LAMBORGHINI CALORECLIMA iXINOX B 32 K 50	nominal heat output: 6,6...28,9 kW heat input (Hi): 6,7...29,5 (drinking water: ...32,0) kW	
LAMBORGHINI CALORECLIMA iXINOX B 35	nominal heat output: 6,6...31,4 kW heat input (Hi): 6,7...32,0 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

Additional proved countries of destination, appliance categories and supply pressures:

AL, MK: I12E3B/P (20, 50 mbar)

BG, MT: I12H3B/P (20, 30 mbar)

GB: I12H3P (20, 37 mbar)

PT: I12H3B/P (20, 37 mbar)

In Albania and Macedonia the CE-marking will be accepted as conformity approval if the Gas Appliance Regulation EU/2016/426 is transferred into national law by Albania respectively Macedonia.

