

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085CL0441Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) <i>EG-Gasgeräte-Richtlinie (2009/142/EG)</i>
Distributor <i>Vertreiber</i>	Lamborghini Calor S.p.A. Via Statale 342, I-44047 Dosso (FE)
Product Category <i>Produktart</i>	Boilers: Condensing water heater (3102)
Product Description <i>Produktbezeichnung</i>	Condensing boiler with fan-assisted burner in modulating operation method and with enclosed combustion chamber
Model <i>Modell</i>	Futura FLC...
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, BY, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, RU, SE, SI, SK, TR, UA
Test Reports <i>Prüfberichte</i>	supplement test: K10742013Z1 from 07.07.2013 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN EN 15502-1 (01.10.2012) DIN EN 15502-2/1 (01.01.2013)
File Number <i>Aktenzeichen</i>	13-0692-GER

28.10.2013 Rie D-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive 2009/142/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Electrical Data
Elektrische Daten

230 V AC, 50 Hz

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E	20 mbar	LU	
I2ELw	20 mbar	PL	
I2H	20 mbar	LV	
I3B	28-30 mbar	ES, FR, GB, IE	
I3B	50 mbar	BE	
I3B/P	28-30 mbar	MT	
I3P	28-30 mbar	ES, FR, GB, IE	
I3P	37 mbar	BE, ES, FR, GB, IE	
II2E+3P	20/25, 28-30 mbar	FR	
II2E+3P	20/25, 37 mbar	BE, FR	
II2E+3P	20/25, 50 mbar	BE	
II2E3B/P	20, 28-30 mbar	PL	
II2ELL3B/P	20, 50 mbar	DE	
II2H3B/P	20, 28-30 mbar	FI, GR	
II2H3B/P	20, 30 mbar	CY, DK, EE, IS, IT, LT, NO, SE, SI, SK	
II2H3B/P	20, 37 mbar	CH, CZ, FI, GR, HR, IT, LT, TR	
II2H3B/P	20, 50 mbar	AT, CH, CY, CZ, HR, IS, SK	
II2H3P	20, 28-30 mbar	ES, GB, IE	
II2H3P	20, 30 mbar	PT, RO	
II2H3P	20, 37 mbar	ES, GB, IE	
II2H3P	20, 50 mbar	RO	
II2HS3B/P	20, 30 mbar	HU	
II2L3B/P	25, 30 mbar	NL	

Installation Codes <i>Installationsarten</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
B23	AT, BE, BG, BY, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, RU, SE, SI, SK, TR, UA	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Futura FLC B 70	nominal heat output: 13,7...64,4 kW nominal heat input (Hi): 14,0...65,5 kW	
Futura FLC B 125	nominal heat output: 22,5...114,0 kW nominal heat input (Hi): 23,0...116,0 kW	
Futura FLC B 220	nominal heat output: 40,2...204,0 kW nominal heat input (Hi): 41,0...207,0 kW	
Futura FLC B 320	nominal heat output: 60,8...294,5 kW nominal heat input (Hi): 62,0...299,0 kW	

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

Additional proved countries of destination, appliance categories and supply pressures:

UA: I2H (20 mbar)

BY, RU: II2H3B/P (20, 37 mbar)

BG, BY, RU: II2H3B/P (20, 50 mbar)

In Belarus, in the Russian Federation and in the Ukraine the CE-marking will be accepted as conformity approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Belarus, Russian Federation respectively Ukraine.