

EU type examination certificate**EU-Baumusterprüfbescheinigung****CE-0085CU0181**Product Identification No.
Produkt-Identnummer**Field of Application**
*Anwendungsbereich*EU Gas Appliances Regulation (EU/2016/426)
EU-Gasgeräteverordnung (EU/2016/426)**Distributor**
*Vertreiber*Ferroli S.p.A.
Via Ritonda 78A, I-37047 San Bonifacio (VR)**Product Category**
Produktart

Boilers: Condensing water heater (3102)

Product Description
Produktbezeichnung

Wall-hunging gas fired central heating condensing boiler with integrated gas burner in modulating operation method and with enclosed combustion chamber

Model
Modell

TORO W...; TORO B...

Countries of Destination
Bestimmungsländer

AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR

Test Reports
*Prüfberichte*supplement test: K 2607 2019 E 4 from 04.02.2020 (TRG)
supplement test: K 2607 2019 B 5_rev1 from 18.03.2020 (TRG)**Test Basis**
*Prüfgrundlagen*EU/2016/426 A III B (09.03.2016)
DIN EN 15502-1 (01.10.2015)
DIN EN 15502-2-1 (01.09.2017)**Date of Expiry / File No.** 11.07.2029 / 20-0099-GER
Ablaufdatum / AZ

12.05.2020 Rie B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E	20 mbar	LU, RO	
I2H	20 mbar	CZ, ES, FR, GR, NL	
I2N	20 mbar	BE, SI	
I3B	30 mbar	ES, IE	
I3B/P	30 mbar	BE, PT	
I3B/P	50 mbar	DE, GR	
II2E+3+	20/25, 28-30/37 mbar	BE, FR	
II2E+3B/P	20/25, 37 mbar	FR	
II2E+3P	20/25, 37 mbar	BE	
II2E3B/P	20, 50 mbar	DE	
II2E3B/P	20, 30 mbar	PL	
II2EK3B/P	20/25, 30 mbar	NL	
II2ELL3B/P	20, 50 mbar	DE	
II2ELw3B/P	20, 30 mbar	PL	
II2H3+	20, 28-30/37 mbar	CH, CY, CZ, ES, GB, GR, IE, IT, LT, PT, SI, SK	
II2H3+	20, 30/37 mbar	TR	
II2H3B/P	20, 30 mbar	CY, CZ, DK, EE, FI, HR, HU, IS, IT, LT, NO, RO, SE, SI, SK	
II2H3B/P	20, 37 mbar	HR, LV, TR	
II2H3B/P	20, 50 mbar	AT, CH, GR, LU, SK	
II2H3P	20, 37 mbar	ES, GB, IE, PT	
II2HM3+	20, 28-30/37 mbar	IT	
II2HM3B/P	20, 30 mbar	IT	
II2HM3P	20, 37 mbar	IT	
II2HS3B/P	25, 30 mbar	HU	
II2L3B/P	25, 30 mbar	NL	

Installation Codes <i>Installationsarten</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
B23	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
TORO W 60	nominal heat output: 14,7...57,0 kW nominal heat input (Hi): 15,0...58,0 kW	
TORO W 80; TORO B 80	nominal heat output: 14,7...72,9 kW nominal heat input (Hi): 15,0...74,4 kW	
TORO W 99	nominal heat output: 18,7...94,7 kW nominal heat input (Hi): 19,0...96,6 kW	
TORO W 120; TORO B 120	nominal heat output: 18,7...110,5 kW nominal heat input (Hi): 19,0...113,0 kW	
TORO W 150; TORO B 150	nominal heat output: 23,6...140,0 kW nominal heat input (Hi): 24,0...143,0 kW	
TORO B 240	nominal heat output: 18,7...221,0 kW nominal heat input (Hi): 19,0...226,0 kW	
TORO B 300	nominal heat output: 23,6...280,0 kW nominal heat input (Hi): 24,0...286,0 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

Additionally tested appliance categories, supply pressures and countries of destination:

ES, FR, GR, PT: I2N (20 mbar)

AL: II2E3B/P (20, 50 mbar)

BG, MT: II2H3B/P (20, 30 mbar)

MK: II2E3B/P (20, 50 mbar)

In the non-EU countries the conformity approval will be accepted if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.

