

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085CU0181

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) EG-Wirkungsgradrichtlinie (92/42/EWG)
Distributor <i>Vertreiber</i>	Ferrol S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Product Category <i>Produktart</i>	Boilers: Condensing water heater (3102)
Product Description <i>Produktbezeichnung</i>	Wall-hung gas fired central heating condensing boiler with integrated gas burner in modulating operation method and with enclosed combustion chamber
Model <i>Modell</i>	TORO W...; TORO B...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	supplement test: K 2607 2019 B 6 from 04.02.2020 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	20-0099-GWR

70228-04-A-DE

12.05.2020 Rie B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-04

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Energy Labelling Energieeffizienzkennzeichnung
TORO W 60	nominal heat output: 14,7...57,0 kW nominal heat input (Hi): 15,0...58,0 kW	
TORO W 80; TORO B 80	nominal heat output: 14,7...72,9 kW nominal heat input (Hi): 15,0...74,4 kW	
TORO W 99	nominal heat output: 18,7...94,7 kW nominal heat input (Hi): 19,0...96,6 kW	
TORO W 120; TORO B 120	nominal heat output: 18,7...110,5 kW nominal heat input (Hi): 19,0...113,0 kW	
TORO W 150; TORO B 150	nominal heat output: 23,6...140,0 kW nominal heat input (Hi): 24,0...143,0 kW	
TORO B 240	nominal heat output: 18,7...221,0 kW nominal heat input (Hi): 19,0...226,0 kW	
TORO B 300	nominal heat output: 23,6...280,0 kW nominal heat input (Hi): 24,0...286,0 kW	